

INSPECTION, MAINTENANCE AND HYDROSTATIC TESTING PERIODS FOR PORTABLE EXTINGUISHERS

The following timetable refers to the NFPA 10 Standard for Portable Fire Extinguishers, 2018 edition (section and paragraph numbers in parenthesis).

Extinguisher Type	Inspection (72.1.2)	Inspection by Certified Individual (7.3)	Maintenance/Internal Exam. (7.3.3.1)	Hydrostatic Testing (8.3.1)
Dry Chemical (Stored Pressure)	30 Days	1 Year	6 Years	12 Years
Carbon Dioxide	30 Days	Maintenance & Conductivity Test at 1 Year	5 Years (Hydro)	5 Years
Halogenated (Halon)	30 Days	1 Year	6 Years	12 Years
Halotron	30 Days	1 Year	6 Years	12 Years
FE-36	30 Days	1 Year	6 Years	12 Years
Water (Stored Pressure)	30 Days	1 Year	5 Years (Hydro)	5 Years
Wet Chemical	30 Days	1 Year	5 Years (Hydro)	5 Years
AFFF (Liquid Charge Type)	30 Days	1 Year	3 Years	5 Years
FFFP (Liquid Charge Type)	30 Days	1 Year	3 Years	5 Years
Dry Chemical (Stainless Steel)	30 Days	1 Year	5 Years (Hydro)	5 Years
Dry Powder	30 Days	1 Year	6 Years	12 Years
Dry Chemical (Cartridge)	30 Days	1 Year	1 Year	12 Years